Titus
The Leader in Air Management

FAN POWERED
ECM (REMOTE) - PWM HEAT,
INCREMENTAL T-STAT

CONTROL NUMBER
AU80

AIR FLOW HI LO

HI

LO

RED (HI)

GREEN (LO)

AUTOMATED LOGIC
ZN341v+

BUS
DO-1
DO-2
DO-3

Analog
Output
+   Gnd

Power

24V ac
Ground

GREEN #18

G

BLUE #18

YELLOW #18

24VAC } TO TRANSFORMER

BLUE #18

WHITE #18 < TO 0 - 10VDC "COMMON" TERMINAL ON REMOTE PWM

PURPLE #18 < TO 0 - 10VDC "SIGNAL" TERMINAL ON REMOTE PWM

RED #18 < TO "INC" TERMINAL ON EHM BOARD

ORANGE # 18 < TO "24VAC" TERMINAL ON REMOTE PWM

ACTUATOR NOTE: PRIOR TO LINKING DAMPER DEPRESS CLUTCH RELEASE BUTTON AND ROTATE ACTUATOR COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE.

PROJECT:

ENGINEER:

CUSTOMER:

DATE:

SPEC. SYM.: