Titus
The Leader in Air Management

SINGLE DUCT
PWM HEAT, INCREMENTAL T-STAT

CONTROL NUMBER
AU70

AIR FLOW

HI   LO

HI

LO

RED (HI)

GREEN (LO)

AUTOMATED LOGIC
ZN141v+

Power

Analog
Output

BUS
DO-1

+   Gnd

24V ac   Ground

GREEN #18

G

BLUE #18

YELLOW #18

24VAC   } TO TRANSFORMER

BLUE #18

RED #18   TO "INC" TERMINAL ON EHM BOARD

ACTUATOR NOTE: PRIOR TO LINKING DAMPER DEPRESS CLUTCH RELEASE BUTTON AND ROTATE ACTUATOR COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE.

PROJECT:

ENGINEER:

CUSTOMER:

DATE:

SPEC. SYM.: