Titus
The Leader in Air Management

AIR FLOW

HI   LO

BLUE #18

24VAC   } TO TRANSFORMER

YELLOW #18

GREEN (LO)

RED (HI)   IN   OUT

GREEN #18   G

FILTER
ONLY
BY OTHERS

RED #18   TO 1st STAGE ELECTRIC REHEAT

WHITE #18   TO (OPT) 2nd STAGE ELECTRIC REHEAT

BROWN #18   TO (OPT) 3rd STAGE ELECTRIC REHEAT

GREEN (LO)

RED (HI)

LO   HI

24VAC
GND
BO-0
BO-1
BO-2
BO-5

IN O /MSET
COM
IN-1
IN-2
COM
IN-3
COM
IN-4

3 4 5 6 7 8   9 10 11 12 13 14 15 16

Alerton VAViH-SD

COM +
COM -

+   -

ACTUATOR NOTE: PRIOR TO LINKING DAMPER DEPRESS CLUTCH RELEASE BUTTON AND ROTATE ACTUATOR COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE.

PROJECT:

ENGINEER:

CUSTOMER:

DATE:

SPEC. SYM.: