Titus
The Leader in Air Management

FAN POWERED
ECM (REMOTE) -
PWM HEAT, INCREMENTAL T-STAT

CONTROL NUMBER
HW A0

AIR FLOW

HI   LO

GREEN (LO)

RED (HI)

TO 0-10VDC "SIGNAL" TERMINAL ON REMOTE PWM — PURPLE #18

TO 0-10VDC "COMMON" TERMINAL ON REMOTE PWM — WHITE #18

TO "INC" TERMINAL ON EHM BOARD — RED #18

TO "24VAC" TERMINAL ON REMOTE PWM — ORANGE #18

HI   LO

DO-1 DO-2 COM AO-1 COM AO-2 UI-1 COM UI-2 UI-3 COM UI-4

Honeywell

PVL4022AS

24VAC 24VAC COM EGND 20DC S-BUS S-BUS NET-1 NET-2

GREEN #18
JUMPER

BLUE #18

GREEN #18   G

TO TRANSFORMER   24VAC

YELLOW #18

ACTUATOR NOTE: PRIOR TO LINKING DAMPER DEPRESS CLUTCH RELEASE BUTTON AND ROTATE ACTUATOR COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE.

PROJECT:

ENGINEER:

CUSTOMER:

DATE:

SPEC. SYM.: