Titus
The Leader in Air Management

AIR FLOW

HI   LO

RED (HI)

GREEN (LO)

G   GREEN #18

LOW IS THE
TOP PORT

BLUE #18

TO TRANSFORMER   24VAC   GREEN #18

YELLOW #18

E H C

SIEMENS
550-405

0

8

1 DO3
2 C
3 DO4
4 AI3
5 C
6 AI4

S
-
+

BLUE #18

TO "INC" TERMINAL ON EHM BOARD

RED #18

TO FAN RELAY OR TO "24VAC" TERMINAL
ON UNITS WITH ECM MOTOR (MANUAL PWM)

ORANGE #18

ACTUATOR NOTE: PRIOR TO LINKING DAMPER SLIDE MANUAL OVERIDE SWITCH TOWARD BASE AND ROTATE COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE. SLIDE MANUAL OVERIDE SWITCH BACK TO ORIGINAL POSITION.

PROJECT:

ENGINEER:

CUSTOMER:

DATE:

SPEC. SYM.: