FAN TERMINAL W/REM ECM LX1, LX5 WITH JOHNSON CONTROLLER / ACTUATOR

CONTROL NUMBER JC35



ACTUATOR NOTE: PRIOR TO LINKING DAMPER DEPRESS MANUAL OVERIDE BUTTON AND ROTATE ACTUATOR COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE.

PROJECT:	DATE:
ENGINEER:	SPEC. SYM.:
CUSTOMER:	