



TO "24VAC" TERMINAL ON REMOTE PWM BOARD

TO 0-10 VDC "SIGNAL" TERMINAL ON PWM BOARD

TO 0-10 VDC "COMMON" TERMINAL ON PWM BOARD

TO 0-10 VDC "COM" TERMINAL ON EHM BOARD

TO 0-10 VDC "SIGNAL" TERMINAL ON EHM BOARD

ACTUATOR NOTE: PRIOR TO LINKING DAMPER DEPRESS MANUAL OVERRIDE BUTTON AND ROTATE COLLAR FULLY CLOCKWISE. LINK DAMPER OPEN. MOTOR TURNS COUNTER CLOCKWISE TO CLOSE.

PROJECT:

ENGINEER:

CUSTOMER:

DATE:

SPEC. SYM.: