

AHRI Directory of Certified Performance

Titus is a charter member company and current participant in the AHRI Directory of Certified Performance. This voluntary certification program was developed by participating manufacturers in conjunction with the former Air-Conditioning and Refrigeration Institute (ARI) in the 1990's. It is currently administrated by the Air-Conditioning, Heating, and Refrigeration Institute (AHRI). The purpose of this program is to provide for the independent verification of manufacturers' published performance data. Only participating products are authorized to bear the AHRI VAV Certification Mark. Certified data may be viewed and downloaded at www.ahrinet.org.

In order to participate in this program, member companies pay annual dues, submit published performance data for all applicable model types, and agree to provide a number of randomly selected product samples for annual rounds of independent testing at the manufacturers' expense. All verification testing is conducted in accordance with ASHRAE Standard 130 'Methods of Testing Air Terminal Units'. These tests are conducted to verify that a manufacturer's published certified ratings are within the test tolerances outlined in AHRI Standard 880 'Performance Rating of Air Terminals'. Any failure to demonstrate the certified performance is punished by additional testing requirements, mandatory performance re-rating, monetary penalties and possible expulsion from the Certified Directory.

Product samples provided for certification testing are standard production PTQS, ATQS, DTQS

units with standard ½ in dual density fiberglass lining (unless otherwise specified) and no optional appurtenances such as add-on attenuators or heating/cooling coils. The certified ratings are measured at the standard operating points under the following test conditions:

PTQS, ATQS, DTQS, PFLS, AFLS, DFLS

- Rated airflow (cfm) – Based on lesser of an inlet velocity of 2000 fpm or the maximum fan flow with 0.25 in wg of downstream pressure
- Rated fan power (watts) – Based on fan operating at the rated airflow with 0.25 in wg of downstream pressure
- Rated Min ΔPs (in wg) – Min ΔPs is the difference between atmospheric pressure and the inlet static pressure at rated airflow with the primary damper full open and the unit fan set to match the primary flow
- Rated ΔPs (in wg) – A static pressure of 1.5 in wg applied to the inlet duct
- Rated sound power by octave band (dB, re 10⁻¹² watts) – Radiated and discharge sound performance conducted in a reverberation room that meets both the broadband and pure tone qualifications of AHRI Standard 220

Unit Size	Rated CFM	Fan Watts	Min ΔPs	Fan Only							Fan Plus 100% Primary							Fan Only						
				Discharge		Radiated Sound Power					Discharge		Radiated Sound Power					Discharge		Radiated Sound Power				
				H	W	2	3	4	5	6	7	2	3	4	5	6	7	2	3	4	5	6	7	
208	500	340	0.10	15	17	63	59	54	47	41	37	67	62	57	51	46	43	77	68	62	60	60	59	
310	900	570	0.16	15	17	62	58	55	49	41	36	70	62	58	52	46	41	73	65	61	57	57	55	
412	1300	700	0.21	15	17	69	64	60	55	48	42	74	67	63	57	51	46	77	72	65	62	62	61	
512	1500	860	0.16	17.5	25	69	63	59	57	51	45	74	67	62	60	53	48	77	68	67	64	63	63	
614	2000	1400	0.17	17.5	25	70	67	61	58	52	47	76	70	64	60	55	50	77	68	67	65	64	64	
716	2400	1800	0.15	17.5	25	76	67	67	62	58	54	80	71	69	64	61	57	81	68	68	66	65	65	

PFLS, AFLS, DFLS

Unit Size	Rated CFM	Fan Watts	Min ΔPs	Fan Only							Fan Plus 100% Primary							Fan Only						
				Discharge		Radiated Sound Power					Discharge		Radiated Sound Power					Discharge		Radiated Sound Power				
				H	W	2	3	4	5	6	7	2	3	4	5	6	7	2	3	4	5	6	7	
208	700	250	0.22	8.75	21	70	60	57	55	47	38	73	70	64	60	54	46	67	66	68	69	76	75	
308	700	350	0.22	8.75	21	66	59	59	50	43	32	73	71	65	60	54	45	78	72	68	66	66	64	
426	1600	800	0.09	8.75	28	64	62	62	60	51	42	70	69	67	66	60	57	67	67	69	70	70	66	

