



- FIELD NOTES:**
1. FIELD WIRING MUST BE COPPER CONDUCTOR, RATED AT 75°C MINIMUM.
  2. PER NFPA70, TRANSFORMER IS FACTORY GROUNDED.
  3. OPTIONAL ITEM. REFER TO ORDER ACKNOWLEDGMENT OR BUILD REPORT FOR OPTION REQUIREMENTS.
  4. L-N (115V, 277V) APPLICATIONS USE SINGLE POLE FUSE BLOCK FOR L1 (BLK), NEUTRAL (WHT) TERMINATIONS ARE MADE AT TRANSFORMER.

**LEGEND**

	QUICK CONNECT, FEMALE
	QUICK CONNECT, MALE
	LEVER NUT
	CONTROL VOLTS WIRE
	LINE VOLTS WIRE
	WIRE HARNESS

UNCONTROLLED DOCUMENT WHEN PRINTED

THIS DRAWING MAY NOT REFLECT THE MOST CURRENT REVISION. PLEASE CHECK TO MAKE SURE DRAWING IS CURRENT.

THIS DRAWING CONTAINS PROPRIETARY DATA. UNAUTHORIZED DISCLOSURE REPRODUCTION, OR USE IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION.

**STANDARD APPLIED TOLERANCES**

WELDING:	LENGTH	±0.063
	ANGULAR	±3°
	SQUARE	±0.063
Cu TUBING:	CUT LENGTH	±0.063
	FORMED LENGTH	±0.125
	FORMED ANGLE	±5°
SHEET METAL:	HOLE DIA	±0.005
	CUT SIZE	±0.031
	CUT ANGLE	±1°
	CUT SQUARE	±0.016
	FORMED DIM	±0.031
	FORMED ANGLE	±3°
	FORMED SQUARE	±0.031

TITLE	WD, DDBC, EH, 1PH, SOLO, 1M	MATERIAL	
-------	--------------------------------	----------	--

REVISION DESCRIPTION		ZONE		DO NOT SCALE DRAWING DIMENSIONS ARE IN INCHES UNLESS OTHERWISE NOTED		SCALE	PART NO.	SHEET	DRAWING NO.	REV
SUBMITTAL RELEASE C						NTS	88-50000-04	4	88-50000	0C
ECR/SQ/TRANSMITTAL NO.	DRAWN BY	DATE	CHECKED BY	DATE						
ECR 3255	SJR	08/21/19	MSS	08/21/19						