



- FIELD NOTES:**
1. FIELD WIRING MUST BE COPPER CONDUCTOR, RATED AT 75°C MINIMUM.
 2. PER NFPA70, TRANSFORMER IS FACTORY GROUNDED.
 3. OPTIONAL ITEM. REFER TO ORDER ACKNOWLEDGMENT OR BUILD REPORT FOR OPTION REQUIREMENTS.
 4. L-N (115V, 277V) APPLICATIONS USE SINGLE POLE FUSE BLOCK FOR L1 (BLK), NEUTRAL (WHT) TERMINATIONS ARE MADE AT TRANSFORMER.

LEGEND

| | |
|--|-----------------------|
| | QUICK CONNECT, FEMALE |
| | QUICK CONNECT, MALE |
| | LEVER NUT |
| | CONTROL VOLTS WIRE |
| | LINE VOLTS WIRE |
| | WIRE HARNESS |

UNCONTROLLED DOCUMENT WHEN PRINTED

THIS DRAWING MAY NOT REFLECT THE MOST CURRENT REVISION. PLEASE CHECK TO MAKE SURE DRAWING IS CURRENT.

THIS DRAWING CONTAINS PROPRIETARY DATA. UNAUTHORIZED DISCLOSURE REPRODUCTION, OR USE IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION.

STANDARD APPLIED TOLERANCES

| | | |
|--------------|---------------|--------|
| WELDING: | LENGTH | ±0.063 |
| | ANGULAR | ±3° |
| | SQUARE | ±0.063 |
| Cu TUBING: | CUT LENGTH | ±0.063 |
| | FORMED LENGTH | ±0.125 |
| | FORMED ANGLE | ±5° |
| SHEET METAL: | HOLE DIA | ±0.005 |
| | CUT SIZE | ±0.031 |
| | CUT ANGLE | ±1° |
| | CUT SQUARE | ±0.016 |
| | FORMED DIM | ±0.031 |
| | FORMED ANGLE | ±3° |
| | FORMED SQUARE | ±0.031 |

| | | | |
|-------|----------------------------------|----------|--|
| TITLE | WD, DDBC, EH, 1PH, SELECT, 1M | MATERIAL | |
|-------|----------------------------------|----------|--|

| | | | | | | | | | | |
|------------------------|----------|----------|------------|-------------------------------------------------------------------------|--|-------|-------------|-------|-------------|-----|
| REVISION DESCRIPTION | | ZONE | | DO NOT SCALE DRAWING DIMENSIONS ARE IN INCHES UNLESS OTHERWISE NOTED | | SCALE | PART NO. | SHEET | DRAWING NO. | REV |
| SUBMITTAL RELEASE C | | | | | | NTS | 88-50000-16 | 16 | 88-50000 | 0C |
| ECR/SQ/TRANSMITTAL NO. | DRAWN BY | DATE | CHECKED BY | DATE | | | | | | |
| ECR 3255 | SJR | 08/21/19 | MSS | 08/21/19 | | | | | | |